

Certificate of Compliance

Certificate Number 20080125-R25348
Report Reference 2008 January 25
Issue Date 2008 January 25

Page 1 of 2



Issued to: Prime Air-Conditioning Industries L L C

Al Quoz Industrial Area-4, Gate No 35
PO Box 76345, Dubai

*This is to certify that
representative samples of*


Dampers for Fire Barrier and Smoke
Aerovac Model FD-11

Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 555, "Fire Dampers."

Additional Information: See addendum for product listings

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.


Look for the UL Classification Mark on the product

Issued by:


Mona Couloute

Underwriters Laboratories Inc.

Reviewed by:


Margaret Figueroa

Underwriters Laboratories Inc.

Certificate of Compliance

Certificate Number 20080125-R25348

Report Reference 2008 January 25

Issue Date 2008 January 25

Page 2 of 2



**Underwriters
Laboratories Inc.**

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Fire Dampers for Use in Static Systems

Model	Hr Class	Damper Mounting Position	Single Section Damper Size, in.		Multiple Section Damper Size, in.	
			W	H	W	H
Aerovac FD-11	3	V	36	36	—	—

Issued by:

Mona Couloute
Mona Couloute

Underwriters Laboratories Inc.

Reviewed by:

Margaret Figueroa
Margaret Figueroa

Underwriters Laboratories Inc.